



Boise City Fire Department Permit Supplemental Information

#46 – Bon Fires

The following list is given to you as a courtesy to help expedite the permit process. Completing these items does not guarantee approval. Full review of the plans you provide followed by a site inspection are still required for approval by the Fire Department.

- BON FIRES**
 - Site plan showing all buildings within 200 feet including area for Bon Fire
 - Minimum clearance to structures or combustible materials will be required.
 - Constant attendance until fully extinguished
 - Minimum of 1 portable extinguisher rated 4A will be required
 - Other requirements may be imposed on a case to case basis.