



Boise City Fire Department Permit Supplemental Information

#27 – Liquid or gas-Fueled vehicles or Equipment in Assembly Buildings

The following list is given to you as a courtesy to help expedite the permit process. Completing these items does not guarantee approval. Full review of the plans you provide followed by a site inspection are still required for approval by the Fire Department.

Per Section 314 International Fire Code

- Batteries are Disconnected
- Fuel in tanks does not exceed one-quarter (1/4) tank or 5 gallons (whichever is least)
- Fuel tanks and fill openings are closed and sealed to prevent tampering
- Vehicles, boats, or other motorcraft equipment are not fueled or defueled inside the building