



## Boise City Fire Department Permit Supplemental Information

### #31 – Open Flames and Candles

The following list is given to you as a courtesy to help expedite the permit process. Completing these items does not guarantee approval. Full review of the plans you provide followed by a site inspection are still required for approval by the Fire Department.

#### Per NFPA 160 and Section 307.4.1 International Fire Code

- Fire Department will need a site plan including:
  - A Narrative Description of the flame effect
  - The Location of flame effect devices to be fired and their controls and control sequence
  - Area affected by the flame effect device
  - Location of the Audience
  - Fuels to be used and means of igniting
  - Storage areas of flammable and combustible materials
  - Fire protection features
  - Emergency plan including egress
  
- All Flame Effect operators shall:
  - be 21 years of age
  - NOT be under the influence of Alcohol, Narcotics, or any other medication, illicit or prescribed, that can impair judgment.
  
- Other things to be prepared for:
  - Any other information required by the Fire Department not already included
  - Portable Fire Extinguisher(s)
  - “NO SMOKING” Signs
  - If available – Video copy of previous similar performance - website link acceptable also